

Wetlands

From: Pasqualini Estimating <estimating@pasqualinico.com>
Sent: Wednesday, May 13, 2020 1:21 PM
To: Todd Penney
Subject: RE: [EXTERNAL] RE: L:\Boston Turnpike\1657-1671\2020- UNDERGRND LP REPLACEMENT

APPLICANT'S EMAIL w/SKETCH
Comments

Todd,

Attached is the PDF that I sketched the location of the USTs to be installed at 1657 Boston Turnpike. As you can see, we will keep the shoring out of the 75' buffer, and push the 10,000 gallon UST to the far end of the tank hole, as to keep it as far away from the buffer line as possible. Please let me know if you have any other questions, or if you would like the full size copy mailed to you. Thanks Todd.

Sean Hanrahan

Pasqualini Construction, Inc.
38 Hatchetts Hill Road
Old Lyme, CT 06371
Office: (860) 434-0811
Cell: (860) 575-6306
estimating@pasqualinico.com

From: Todd Penney [mailto:tpenney@coventryct.org]
Sent: Wednesday, April 29, 2020 3:01 PM
To: Pasqualini Estimating <estimating@pasqualinico.com>
Subject: RE: [EXTERNAL] RE: L:\Boston Turnpike\1657-1671\2020- UNDERGRND LP REPLACEMENT

Sean,

Can I ask you to sketch on page 2 of the attached pdf the new tank locations in red. A picture is easier for IWA members. The pdf is formatted at 11x17 page size.

You can scan and email back to me or send in the hard copy to me.

Todd M. Penney, P.E.
Town Engineer/Wetlands Agent
Town of Coventry
860-742-4078

From: Pasqualini Estimating <estimating@pasqualinico.com>
Sent: Wednesday, April 29, 2020 7:13 AM
To: Todd Penney <tpenney@coventryct.org>
Subject: RE: [EXTERNAL] RE: L:\Boston Turnpike\1657-1671\2020- UNDERGRND LP REPLACEMENT

Todd,
To answer your questions:

APPLICANT'S COMMENT RESPONSE
4/29/2020

1&2: The new tanks will go in the same area as the removed tanks, but since there are only 2 USTs going back in, they will be shifted as far towards the road as possible, as to remain completely out of the 75 foot wetlands buffer.

3: The tanks are not leaking as of my knowledge. They are being replaced per the state's requirements of a 30 year tank life.

4: The excavation shoring will be removed after tanks have been installed.

5: We will not be reusing the soil excavated from the tank grave, it will be hauled off site. It may be stockpiled for a short time period, just for ease of excavation, most likely near the building on the tank side of the canopy.

Let me know if you have any other questions. Thanks.

Sean Hanrahan

Pasqualini Construction, Inc.

38 Hacketts Hill Road

Old Lyme, CT 06371

Office: (860) 434-0811

Cell: (860) 575-6306

estimating@pasqualinico.com

From: Todd Penney [<mailto:tpenney@coventryct.org>]

Sent: Friday, April 24, 2020 11:31 AM

To: Pasqualini Estimating <estimating@pasqualinico.com>

Cc: Brigit Tanganelli <btanganelli@coventryct.org>; Heidi Leech <hleech@coventryct.org>

Subject: RE: [EXTERNAL] RE: L:\Boston Turnpike\1657-1671\2020- UNDERGRND LP REPLACEMENT

The application was "received" by the Agency on the 22nd. I will send out the minutes when it becomes available. The application will be acted on at the May 27th meeting.

See the site plan I put together for the application. Comments from me and the Agency:

1. Where are the two new tanks going to replace the 3 existing?
2. Can the two new tanks be shifted to the far north limits of excavation to move them nearly completely out of the 75 foot upland review area?
3. Are is the tank replacement a maintenance requirement or are they leaking?
4. Will you be keeping your excavation shoring in place or removing?
5. Where will you be stockpiling the excavation spoils? Will you be reusing material or hauling off site?

Todd M. Penney, P.E.
Town Engineer/Wetlands Agent
Town of Coventry
860-742-4078

Todd Penney COMMENTS
4/24/2020

From: Pasqualini Estimating [<mailto:estimating@pasqualinico.com>]

Sent: Friday, April 24, 2020 10:57 AM

To: Todd Penney <tpenney@coventryct.org>

Cc: Brigit Tanganelli <btanganelli@coventryct.org>; Heidi Leech <hleech@coventryct.org>

Subject: [EXTERNAL] RE: L:\Boston Turnpike\1657-1671\2020- UNDERGRND LP REPLACEMENT

Good Morning Todd,

I am contacting you regarding the Tank replacement project at 1657 Boston Turnpike, that had to go through Wetlands permitting. I gave the owner the information needed to apply for the wetlands permit, to which he told me he has submitted the application. I just wanted to double check to make sure that you got everything that you needed, and the application was taken in for review on the 22nd as planned. Thanks Todd.

Sean Hanrahan