



Town of Coventry
Office of Land Use and Development
 1712 Main Street • Coventry, CT 06238
 Phone: 860 742-4062 Email: Wetlands@coventryct.org

Stormwater Mitigation Feature Inspection Report

<p>Submit this form via email or mail by May 1st each year</p> <p style="font-size: small;">Submit via email: Wetlands@coventryct.org Submit via mail: Coventry Land Use Office, Attn: Wetlands 1712 Main Street, Coventry, CT 06238</p>				
Inspection Details:	Address:	Inspection Date:		
	Inspector Name:	Inspector Phone #:		
	Permit Number (if applicable):			
	Stormwater Feature Inspected:			
	Inspection Type (please circle):			
	Pre-rain	Monthly	Semi-annually	Annually
Overall Feature Condition:	<input type="checkbox"/> Great. Feature is maintained and is functioning properly.	<input type="checkbox"/> Good. Some maintenance (weed trimming, particle removal) needed.	<input type="checkbox"/> Poor. Maintenance required to maintain BMP functionality.	
Visual Assessment of Inlets and Outlets (pipes, spillways, trenches, basins, etc.):	<input type="checkbox"/> Drain inlets and outlets are clear of sediment and debris, no maintenance required.	<input type="checkbox"/> Some accumulation of sediment and debris, minor maintenance needed.	<input type="checkbox"/> Significant blockage with sediment and debris. Maintenance required.	
Sediment and Particle Accumulation:	<input type="checkbox"/> Sediment/particulate accumulation less than 1.0" throughout feature.	<input type="checkbox"/> Sediment/particulate accumulation 1.0 – 3.0" throughout feature. Functionality is not impaired.	<input type="checkbox"/> Sediment covers vegetation greater than 3.0" in any location. Maintenance required.	
Evidence of Erosion/Channeling:	<input type="checkbox"/> No visible loss of specialized soil media. No rill erosion or scour observed.	<input type="checkbox"/> Soil media requires infill/repair. Minor erosion visible.	<input type="checkbox"/> Soil media significantly impacted. Rill erosion evident. Maintenance required.	
Drainage Condition:	<input type="checkbox"/> No standing water visible 24-hours following 0.50" storm event.	<input type="checkbox"/> No standing water visible 72 hours following 0.50" storm event.	<input type="checkbox"/> Standing water present longer than 72 hours following 0.50" storm event.	
Vegetative Cover:	<input type="checkbox"/> 75-100% of vegetation is healthy and growing. Minimal weeds present. Vegetation is maintained at specific height.	<input type="checkbox"/> 50-75% of vegetation is healthy. Some weeds present. Vegetation may need to be trimmed.	<input type="checkbox"/> 50% or less of original vegetation cover remains. Weeds or bare soil present. Undesirable vegetation growth. Invasive species present.	

Additional Information

Date any additional maintenance will be completed:

Additional Notes:

Submission of photos is required for documentation. If submitting photos via email, please label/name the photo with the date the photo was taken and what Stormwater Feature is pictured. Descriptions can also be provided in the “Additional Notes” area above.

For Land Use Office Only:

Date Received:

Staff Reviewer:

Permit Number:

Additional Comments:

Please contact Wetlands@coventryct.org/860-742-4062 if you have any questions or would like resources pertaining to the maintenance of your stormwater feature.