



Town of Coventry

Office of the Town Engineer

Todd M. Penney, P.E. - Town Engineer | Wetlands Agent

1712 Main Street • Coventry, CT 06238

Phone: 860 742-4078

Fax: 860 742-5467

Email: tpenney@coventryct.org

Date: February 11, 2021

TM Penney/MGGosselin

To: Scott Shroyer, Applicant/Owner

Re: Review comments on 20-03W (MOD 01) – 90 Hemlock Lane – Repair existing stone lake wall

The Inland Wetlands Agency (IWA) reviewed your proposal regarding Lake Wall repair work at its January 27, 2021 meeting and requested a more formal application to be submitted. **Additional materials that should be submitted include a description, location of work and additional existing condition pictures.**

Our major concern with the application activities is eliminating the discharge of sediment into the lake.

We recommend the following conditions be considered by the Agency if they vote in the affirmative:

1. Hold a preconstruction meeting with the applicant and any other subcontractors prior to the start of activities to review construction sequencing.
2. All activities involving work at the lake edge will require staff oversight. All coordination for staff time on site will be schedule at least a week in advance. Failure to coordinate staff's presence will be considered a violation of the permit and be subject to a cease and desist order.
3. Restore finished surfaces with erosion control blanket within 5 days of completion of the wall area, complete wall in sections.
4. Additional erosion and sedimentation controls maybe required as site conditions/weather warrant by the Wetlands Agent staff.

The application will be on the February 24, 2021 Regular Meeting Agenda. It would be helpful to have any responses to these comments and additional application materials submitted prior to the meeting. You may reach Todd at the contact information above and/or Mindy at 860-742-4062, wetlands@coventryct.org.