

Melinda Gosselin

From: Todd Penney
Sent: Friday, November 13, 2020 1:32 PM
To: Eric Trott; 'JOSHUA BEEBE'
Cc: Alexa Gorlick; Joe Callahan; Wetlands
Subject: RE: [EXTERNAL] Re: 89 Flanders Rd
Attachments: SITE CONDITION AS OF 2020-11-13.pdf; IMG_6625.JPG

Josh,

See attached. Please sketch on here where the chicken coops are and where you proposed to extend the limits of clearing along Flanders River Road and submit to the Land Use office. **As you can see the silt fence is just outside of the 75 Foot Upland Review Area. You need to stay outside of that 75 foot upland review area.**

You can send the pdf to Staples to print at 11 x 17. The plan is 1 inch is equal to 40 feet.

Based on my comp; the current area of the disturbance is ~14,560SF.

Finally, the silt fence is not installed correctly. It needs to be trenched into the ground by ~6" to prevent sediment discharge from going underneath it. I think from the photo, you can agree that it currently wont impede any sediment discharge.

Todd M. Penney, P.E.
Town Engineer/Wetlands Agent
Town of Coventry
860-742-4078

From: Todd Penney
Sent: Thursday, November 12, 2020 6:37 PM
To: Eric Trott <etrott@coventryct.org>; 'JOSHUA BEEBE' <joshb@kahntractor.com>
Cc: Alexa Gorlick <AGorlick@coventryct.org>; Joe Callahan <jcallahan@coventryct.org>; Wetlands <wetlands@coventryct.org>
Subject: RE: [EXTERNAL] Re: 89 Flanders Rd

Josh,

Just a FYI, I am hoping to be out there by 8am tomorrow. It should be only ~15minutes to do the GPS locating of the silt fencing.

I went back to my e-folder and found this email from August 2019 regarding the wetlands and As of Right. I will hope to get that plan done later tomorrow afternoon before I leave for the day.

Todd M. Penney, P.E.
Town Engineer/Wetlands Agent
Town of Coventry
860-742-4078

From: Eric Trott <etrott@coventryct.org>
Sent: Thursday, November 12, 2020 11:36 AM